

CERTIFICATE OF COMPLIANCE

FOR

Osteogenics Biomedical, Inc.

Lubbock, TX 79424

Cleanroom # 1

The above referenced clean zone has successfully passed the minimum requirements to meet the ISO class listed below per ISO Standard 14644-1:1999 for particle count testing of cleanrooms and associated controlled environments.

Particle Size: **0.5 microns and larger**

ISO Class: **7**

Occupancy State: **Operational / Dynamic**

Date of Certification: **May 17, 2016**

Due for Retest: **May 2017**

Certified by: **Jerome Eppinger**

Test Report #: **ENV0608161127DE**

